

FIRE SAFETY CERTIFICATE

No./MCD/FAES/2025

Date 04/09/2025.

Certified that the EKLAVYA MODEL RESIDENTIAL SCHOOL HIRVE TAL. MOKHADA DIST. PALGHAR at HIRVE, TAL. MOKHADA, DIST. PALGHAR comprised of 11 rooms on the Ground floor owned/occupied by EKLAVYA MODEL RESIDENTIAL SCHOOL HIRVE TAL. MOKHADA DIST. PALGHAR have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the photos submitted by the school authority on 28/08/2025. The fire audit report submitted by them state that, they have installed 06 Fire Extinguishers. The school administration needs to be installed the additional equipment as per fire audit report as follows.

1. fire Alarm.
2. Manual Call Point.
3. Hooper
4. smoke detector
5. fire extinguisher.

Hence the Fire safety certificate is issued by this office on their request for the period of Six months from 04/09/2025 up to 03/03/2026.

Issued on 04/09/2025. by FIRE AND EMERGENCY DEPARTMENT OF MUNICIPAL COUNCIL DAHANU

Strike out whichever is not applicable



Signature with seal

Name Pyarehand Adiwaj

Designation fire station officer

Department fire and Emergency Services

of Municipal Council Dahanu.

To,

Eklavya Model Residential School, Mokhada, Tal. Mokhada, Dist. Palghar.

ENDORSEMENT

The no objection Certificate issued by Fire service stand cancelled and annulled due to

(Reason to be recorded)


Principal
Eklavya Model Residential School
Mokhada, Tal Mokhada Dist Palghar